

# ELCTRICAL EQUIPMENT TESTING (PAT)

Certificate Reference

52689

**CLIENT DETAILS**Registered at: [www.pro-disco.com](http://www.pro-disco.com)**DATE**

29/05/2011

**DETAILS OF THE CONTRACTOR RESPONSIBLE FOR THE TESTING**

Trading Title ECAB Hampshire

Registration Number

58851593

Address Waterloo Street, Southampton, SO51 2 R

**For the inspection and testing of the electrical equipment**

Name

Chris Wright

Position

Test Engineer

Signature

Test Equipment

Seward P Test 50

Serial Number

803968

Retest Date:

29/05/2012

Item / Description	Class	Visual	Earth	Insulation	Repair
001 230v Extension Lead	Class 1	Pass	0.04 OHMS	<20 MOHMS	
002 230v Extension Lead	Class 1	Pass	0.05 OHMS	<20 MOHMS	
003 230v Extension Lead	Class 1	Pass	0.03 OHMS	<20 MOHMS	
004 230v IEC Lead	Class 1	Pass	0.05 OHMS	<20 MOHMS	
005 230v IEC Lead	Class 1	Pass	0.05 OHMS	<20 MOHMS	
006 230v IEC Lead	Class 1	Pass	0.02 OHMS	<20 MOHMS	
007 230v IEC Lead	Class 1	Pass	0.05 OHMS	<20 MOHMS	
008 230v IEC Lead	Class 1	Pass	0.02 OHMS	<20 MOHMS	
009 230v IEC Lead	Class 1	Pass	0.05 OHMS	<20 MOHMS	
022 Mixer	Class 1	Pass	0.06 OHMS	<20 MOHMS	
023 Pioneer PSU	Class 1	Pass	0.06 OHMS	<20 MOHMS	
024 Radio Mic PSU	Class 1	Pass	0.05 OHMS	<20 MOHMS	
031 Lighting	Class 1	Pass	0.02 OHMS	<20 MOHMS	
032 Lighting	Class 1	Pass	0.05 OHMS	<20 MOHMS	
033 Lighting	Class 1	Pass	0.05 OHMS	<20 MOHMS	
034 Lighting	Class 1	Pass	0.02 OHMS	<20 MOHMS	
035 Lighting	Class 1	Pass	0.05 OHMS	<20 MOHMS	
035 Lighting	Class 1	Pass	0.05 OHMS	<20 MOHMS	
036 Lighting	Class 1	Pass	0.05 OHMS	<20 MOHMS	
037 Lighting	Class 1	Pass	0.05 OHMS	<20 MOHMS	
038 Lighting	Class 1	Pass	0.05 OHMS	<20 MOHMS	
039 Lighting	Class 1	Pass	0.05 OHMS	<20 MOHMS	
050 Haze Machine	Class 1	Pass	0.04 OHMS	<20 MOHMS	